

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/WZ/2021/ 1974

Dated: 27/09/2021

To,

Golden Falcon Industries Limited
Plot No. 71/3, Rama Road
Najafgarh Industrial Area
New Delhi 110015

Subject: - Issue of Fire Safety certificate in respect of M/s Golden Falcon Industries Limited Plot No. 71/3, Rama Road, Najafgarh Industrial Area, New Delhi 110015.


Sir,

Please refer to your E mail dated 18/08/2021 on the subject mentioned above. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 04/09/2021 in the presence of Sh. Shachi Bhasin to check the functioning of fire safety arrangements required as per guidelines issued by this deptt. Vide letter No. F6/DFS/MS/BP/2021/1050 dated 13/05/2021. During inspection, it has been observed that the building is comprised of Basement + Ground & 1st Floor served by 02 nos. of staircase serving from basement to ground level 1.25 mts each, 02 nos. of suitcase of width 1.25mts each are serving from ground to terrace and one staircase of 1.25 mts width is serving from ground to first floor. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Over Head water storage tank, Underground water tank capacity are provided. However the following shortcomings were observed: -

1. Fire check door is not provided in the stair case.
2. Internal Hydrants & First – Aid Hose reels are provided but not functional.
3. Automatic Sprinklers System provided but not functional.
4. Electric Pump & Diesel pump of capacity 2280 lpm each Jockey pump 180lpm, Terrace pump 900 lpm are yet to be installed.
5. Exit Signage's are not provided.
6. Ventilation system in basement floor is yet to be installed.
7. Draw off connection, Fire service inlet are not provided.
8. LT/HT pannel in basement is not provided with special Fire protection arrangements.

In view of above Shortcomings, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements Shall be at the risk and liabilities of the Owner/occupier. The Building authority /statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy To: -

1. The Executive Engineer – I(Bldg.)HQ, NDMC, 9th Floor Civic Center Minto Road, New Delhi-110002.
2. The DY. Director (Bldg), DDA, INA, Vikas sadan, New Delhi.