

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2021/ Cans/ 1976

Dated: 27/09/2021

To,

Sh. S.S Rawat (President),
Kalka C.G.H.S Ltd.
Plot No 31, Sector – 6,
Dwarka, New Delhi – 110075.

Subject: Renewal of Fire Safety Certificate iro Kalka C.G.H.S Ltd. Located at Plot No 31,
Sector – 6, Dwarka, New Delhi – 110075.

Sir,

Please refer to Email dated 10/08/2021 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer from this department on 26/08/2021 for the renewal of fire safety certificate. During course of inspection the following shortcomings were observed:

1. The internal road found encroached due to planters & installation of DG set etc.
2. Staircases are found locked at terrace & blocks are found not connected to each other at terrace level.
3. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers.
4. Hose reel hose & internal hydrant found nonfunctional.
5. Yard hydrants found removed.
6. MOEFA found nonfunctional.
7. PA System found Nonfunctional.
8. Terrace Pump of 450 lpm with 40m head found nonfunctional
9. Communication system & fireman ground switch are provided in the lift but found nonfunctional.

In view of the above shortcomings Fire Safety Certificate can not be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully,


(Atul Gang)
Director
Delhi Fire Service

Copy to:- The Joint Director, DDA, Vikas Sadan, INA, New Delhi.