

c/20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/ 514

Dated: 24/09/2021

To,

The Principal,  
Dr. Zakir Husain Memorial Senior Secondary School,  
Jafrabad, Delhi-110053

**Subject:- Request for renewal of N. O. C. regarding fire safety measures in the school.**

Sir,

With reference to your letter No. DZHS/D/DFS/NOC/21/217 dated 13/08/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Dr. M. M. Khan on dated 06/09/2021. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-

1. The fire pump was not functional.
2. Hose Reel was not functional and also hose reels are required to be provided at ground & IIIrd floor.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)  
Dy. Chief Fire Officer



Copy to:-

The Joint Director of Education, (Land & Estate),  
Directorate of Education, Lucknow Road,  
Delhi-110054