

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

254

No.F6/DFS/MS/School/NDZ/2021/ 527

Dated: 29/09/2021

To

1. Mrs. Manju Rani (Vice Principal)
Govt. Girls Sr. Sec. School, Pataudi House, Daryaganj,
Delhi - 02. School Code : 2127020.
2. Mrs. Madhu Mitali (Vice Principal),
Govt. Girls Sr. Sec. School (U.M.), Kalan Mahal,
Darya Ganj, Delhi (School ID no. 2127027).

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Govt. Girls Sr. Sec. School (U.M.), Kalan Mahal, Darya Ganj, New Delhi (School ID no. 2127027) & Govt. Girls Sr. Sec. School, Kalan Mahal, Darya Ganj, New Delhi (School ID no. 2127020**

Sir,

With reference to email letter dated 18.09.2021 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (SPM) from this department on 14.09.2021 in the presence of Mrs. Madhu Mitali (Vice Principal), GGSSS (UM) and Mrs. Manju Rani (Vice Principal), GGSSS and it was observed that the building is comprised of ground + 3 upper floors and two schools namely GGSSS (School code: 2127020) and GGSSS (Urdu Medium) (School Code: 2127027) are running on ground + 1st and 2nd + 3rd floors respectively. During the inspection following shortcomings were observed:-

1. The school building is not accessible to fire engine as approach road width is less than 6 meters.
2. First-aid-hose reels not provided at 2nd and 3rd floor.
3. Fire pump having capacity 450 LPM & head 40 mtrs. not provided.
4. Overhead tank capacity 10,000 liters for firefighting not provided.
5. Exit signages not provided.

Since both the schools are located in the same building, the fire safety norms for school running at higher height/ floors are applicable to the entire building.

In view of above shortcomings, the request for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

erc
28/9