

C-9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2021/ 516

Dated: - 27/09/2021

To

The Principal
Gyan Prakash Saraswati Vidya Mandir,
A- Block, Meera Bagh,
New Delhi-110087.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o Gyan Prakash Saraswati Vidya Mandir located at A- Block, Meera Bagh, New Delhi-110087.

Sir,


This is in reference of Email dated 24/08/2021 received in this department on the subject cited above. In this connection, it is to inform you that the school building has been inspected by the officer concerned of this department in presence of Mrs. Mamta Sharma, Principal, on 03/09/2021 to check the fire safety arrangements provided in the building.

During the inspection, it was also observed that the building complex is comprised of Ground + One upper floor. The following shortcomings have been observed:

1. 04 nos Fire Extinguishers are provided against required 06 nos fire extinguishers.
2. A Pantry with LPG Cylinder running in class room at ground floor shall be removed.
3. Fibre sheet shed provided in the premises shall be removed.
4. Storage of combustible material in the stairs shall be removed.
5. One Staircase found locked at terrace level & the same should not be locked during the occupancy of school building.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Director of Education, NDMC, Civic Centre, Minto Road, New Delhi.