

C32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2021/ 520

Dated: 28/09/2021

To

The Principal,  
Indraprastha Modern Public School,  
C-374A, New Ashok Nagar, Delhi-91.

**Sub: Regarding Renewal of FSC in r/o Indraprastha Modern Public School located at C-374A, New Ashok Nagar, Delhi - 110091.**

Sir,

This has reference to your letter no. nil dated 08/09/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premises was visited by the officer concerned of this department on 16.09.2021 in the presence of Mr. Dheer Singh (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested/checked and found following observation:-

1. Hose reel found not functional.
2. Fire pump found not functional.
3. Overhead water tank capacity of 4,000 liter provided against required capacity of 10,000 liter.
4. Exit signages not provided.
5. 6 rooms found constructed and in use at 4<sup>th</sup> floor.

As it is a case of addition of one floors, Hence issue of Fire Safety Certificate is rejected. You are hereby directed to forward & sanction plan through building authority.

Yours faithfully

  
(Atul Garg)

Director  
Delhi Fire Service

Copy to:-

The Dy. Director of Education,  
D-Block, Anand Vihar, Delhi.

