

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/2021/ 521

Dated: 28 /09/2021

To

The Principal,  
Mother Marry Public School,  
292-B, Main Road, Mandawali, Delhi-92.

**Sub: Regarding Renewal of FSC in r/o Mother Marry Public School, 292-B, Main Road, Mandawali, Delhi-92.**

Sir,

This has reference to your email dated 09/09/2021 on the subject cited above. In this regard, it is to inform you that the site was re-inspected by the officer concerned of this department on 22/09/2021 in the presence of Mr. Gaurav Verma and observed that no progress was seen on the observations communicated by this department vide letter no. F6/DFS/MS/School/2021/472 dated 07/09/2021 (photo copy enclosed).

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully



(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Encl:- as above.

Copy to:-

The Director (Education),  
EDMC, 419, Udyog Sadan,  
Patparganj Industrial Area, Delhi - 92.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2021/ 472

Dated:-07/09/2021

To

The Principal,  
Mother Marry Public School,  
292-B, Main Road, Mandawali, Delhi-92.

**Sub: Regarding Renewal of FSC in r/o Mother Marry Public School, 292-B, Main Road, Mandawali, Delhi-92.**

Sir,

This has reference to your email dated 16/08/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 31/08/2021 in the presence of Mr. Gaurav Verma and observed that following shortcoming was observed :-

1. Pump provided but not functional.
2. Hose reel hose/Hydrant provided but not functional.
3. Exit signage not provided.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully



(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

o/c  
m

Copy to:-

The Director (Education),  
EDMC, 419, Udyog Sadan,  
Patparganj Industrial Area, Delhi - 92.