

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2021/ 525

Dated: 29/09/2021

To,

The Principal,  
Siddharth Public school, RZH-330B,  
Street No. 11, Raj Nagar – II Palam colony,  
New Delhi – 110045.

Subject: Renewal of Fire Safety Certificate iro Siddharth Public school, RZH-330B, Street No. 11, Raj Nagar – II Palam colony, New Delhi – 110045.

Sir,

Please refer to your Email dated 29/07/2021 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 20/09/2021 for the renewal of fire safety certificate. During course of inspection the following shortcomings were observed:

1. Passage to Stairs found not clear. The stairs must be free from any obstruction & free from lock & key.
2. Overhead water storage tank of 2000 litres provided in place of required 5000 litres
3. Terrace pump found not functional and not in auto mode.

In view of the above shortcomings Fire Safety Certificate can not be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully,



(Sunil Chaudhary)  
Dy. Chief Fire officer  
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054

h/c  
22/9