



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/WZ/2021/ 517

Dated: - 27/09/2021

To

The Principal
St. Mary's Senior Secondary School
Ambica Vihar (Near GH-13),
Paschim Vihar, New Delhi-110087.

Sub.:- Regarding renewal of Fire Safety Certificate in r/o St. Mary's Senior Secondary School located at Ambica Vihar (Near GH-13), Paschim Vihar, New Delhi-110087.

This is in reference of Email dated 06/09/2021 received in this department on the subject cited above. In this connection, it is to inform you that the school building have been inspected by the officer concerned of this department in presence of Ms. Sylvania Paul (Principal) on 13/09/2021 to check the fire safety arrangements provided in the building.

During the inspection, it was also observed that the building complex is comprised of Basement, Ground plus three upper floors. The following shortcomings have been observed:

1. Width of Main Gate is reduced to 4 m & earlier it was 6 m against the requirement of 4.5 m.
2. Smoke Management system found removed from basement.
3. First Aid Hose Reel found non functional.
4. Terrace Fire pump found non functional.
5. Overhead tank specifically for firefighting found used for other purpose.
6. Exit Signages are not adequate.
7. Lift leading to basement should be protected with lift lobby providing Fire Check Door.
8. Communication in lift Car, Fireman Switch and Lift Signage not provided.
9. A Pantry with LPG (commercial cylinder) is running in basement under the staircase shall be removed.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Director of Education, NDMC, Civic Centre, Minto Road, New Delhi.

Handwritten signature and date: 27/9/21
Handwritten initials: DC
Handwritten date: 27/9/21