

20510001/DLW

- 11.2

c/53

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No.F6/DFS/MS/SZ/2021/515

Dated.27/09/2021

To,

The Executive Engineer (Building),
MCD Zone officer, Najafgarh,
Dhansa bus stand Najafgarh,
New Delhi.

Subject: Request to verify the height of the Building Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075

Sir

This has reference of party letter / Email Dated 10/08/2021 for the renewal of fire safety certificate in r/o above mentioned school.

In this regard it is to inform you that inspection of the above said school was carried out by the officer concerned from this department on 25/08/2021 and observed that the school has constructed 3 temporary Rooms on the terrace.

In view of the above it is requested that height of the school building may kindly be measured and informed to Delhi Fire Service for taking further action at our end.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-The Principal Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075.