

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/BP/2021/ 2005

Dated: 29/9/2021

To

✓ The Authorized Signatory,
M/s R S Hospitality Services,
R-846, New Rajinder Nagar,
New Delhi – 110060.

Sub: To issue Fire NOC for obtaining Health Trade License from DHO Karol Bagh Zone, North DMC for running the Gym at R- 846, Basement, New Rajinder Nagar, New Delhi – 110060.


Sir,

Please refer your letter No. Nil dated Nil on the subject cited above. In this connection it is to inform you that the building plans, submitted by you have been examined and observed following shortcomings:

1. Staircases/exits are not shown in the basement.
2. Fire safety arrangements, as stipulated in NBC-Part-4 are not marked on the plan.

Therefore, the plans are returned to you in original with request to rectify the above shortcomings and re-submit the proposal for further consideration in the matter.

Yours faithfully


(Virendra Singh)
Dy. Chief Fire Officer
Ph:011-23412225

Copy to:

The Deputy Health Officer,
Public Health Department,
Karol Bagh Zone, Anand Parbat,
New Delhi – 110005.

- for information please.