

C-58

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2021/ 652

Dated: 24/09/2021

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Standard Guest House, situated at 17, N.S Marg, Darya Ganj, Delhi.**

Sir,

With reference to online application I.D. no. 2021082518942 dated 25.08.2021 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 10.09.2021 in the presence Mr. Satish (Manager) and it was observed that building is comprised of ground + mezzanine + 03 upper floors. During inspection, following shortcomings were observed.

1. First Aid Hose reels found non functional.
2. Fire pump found non functional.
3. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


23/9/21

((Dr. S.K. Tomar))

Dy. Chief Fire Officer

Tel: 011-23412025



Copy to:-

The Licensee,

M/s Standard Guest House, situated at 17, N.S Marg, Darya Ganj, Delhi.