

2
C-26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/EH/2021/SZ/ 422

Dated 27/09/2021

To,

Sh. Rajesh Kumar Aggarwal,
M/s Bite Bikaner, C-1/1, First Floor,
Janakpuri, New Delhi-110058.

Sub: - Regarding grant of NOC from fire safety point of view in r/o M/s Bite Bikaner, C-1/1, First Floor,
Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter no. ID No. 2021030611013 dated 29/06/21 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned assembly building from fire safety point of view. At the time of inspection Sh. Rajesh Kumar Aggarwal (owner) was present and it was observed that the building is comprised of ground plus three upper floors but restaurant is running at first floor only. During the course of inspection, the following points / shortcomings were noticed:

1. Both the staircase shall be provided 1.5 m wide.

In view of above, the assembly building cannot be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

9/9/21

Copy to:-

Dy. Health Officer (West Zone),
S.D.M.C, office of the Dy. Health Officer,
Shivaji Enclave, Rajouri Garden, New Delhi-110027.