

2-15
C16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/WZ/2021/ 423

Dated: 28/09/2021

To,

M/s The Market Palace (A unit of Rain Tree Grill)
Shop No. A/7 A/8 1st Floor
Main Najafgarh Road New Delhi-110015.

Sub: - Inspection report in r/o M/s The Market Palace (A unit of Rain Tree Grill) Shop
No. A/7 A/8 1st Floor Main Najafgarh Road New Delhi-110015.

Sir,

Please refer to your online application no.: -2021071715368 dated:- 17/07/2021 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 02/09/2021 in the presence of Sh. Vikas (General Manager) to see the functioning of existing fire safety arrangements provided in the building. During inspection, It has been observed that the building is comprised of Basement + Ground + 03 Upper Floors was issued FSC vide letter No. F6/DFS/MS/2018/WZ/BNQT/1413 dated 15/06/2018 for Ground & First Floor only. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Terrace Pump, Over Head water storage tank & Exit signage are provided. However the following shortcomings were observed:-

1. First Aid Hose Reels are provided but not functional.
2. MOEFA is provided but not working.
3. Main fire pump of capacity 450lpm is provided but not functional & not on auto mode.
4. Over head water storage tank capacity 3000 ltrs is provided against the requirement of 10,000 ltrs.
5. Exit signages are found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements Shall is at the risk and liabilities of the Owner/occupier. The Licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

28/09/2021

Copy to: -

1. Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi.
2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.