

C 85

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/WZ/2021/434

Dated: 05/10/2021

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.

Sub: - Inspection report in r/o M/s. Tippling Street (A unit of D.K. Plaza) located at A -12,
Vishal Enclave, Rajouri Garden, New Delhi-110027.

Sir,

This is in reference to your online application received through MHA portal vide Id- 2021072015507 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 06/09/2021 in the presence of Sh. Kawaljeet Singh (Director) to Check the Provisioning of fire safety arrangements provided in the building.. During the course of inspection, it was observed that the said restaurant is running at 1st, 2nd & 3rd Floor of a Building Comprised of basement, Ground + 3 upper floors. Fire safety arrangements such as fire extinguisher, First Aid hose reels, MOEFA, Hydrant System, Terrace Pump, Exit Singes etc found provided. This department has issued FSC for 1st & 2nd Floor Vide this department letter No. F6/DFS/MS/2018/EH/WZ/2475 dated 02/11/2018. However the following shortcomings were observed: -

1. Two stair cases having width 0.85mts & 1.10mts against the required width of 2.0mts & 1.5mts.
2. Width of door sizes 1.0 mts, 0.96mts & 0.85mts against the requirement of 2.0mts & 1.5mts.
3. Main fire pump of 2280lpm, jokey pump of 180lpm & Stand by pump of 2280lpm are not provided.
4. Underground water storage tank capacity 1, 00,000 ltrs is not provided.
5. Ventilation system is not working.
6. Draw off connection is not provided.

In view of above Shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the Owner/occupier. The Licensing issuing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully


Anil Goyal
Director
Delhi Fire Service
o/c [Signature]
20/09/2021

Copy to: -

1. M/s. Tippling Street (A unit of D.K. Plaza)A-12, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.