

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

G-19

No. F6/DFS/MS/EH/MN/2021/419

Dated: 27/09/2021

To,

Authorized Signatory
M/s : Theobroma Foods Pvt. Ltd.UGF,17
Adarsh Bhawan Co-Op. House Building Society Ltd
Main club Road, Punjabi Bagh Extn., New Delhi-110026.

Subject: - Inspection report of M/s : Theobroma Foods Pvt. Ltd.UGF, 17, Adarsh Bhawan Co- Op. House Building Society Ltd., Main club Road, Punjabi Bagh Extn., New Delhi-110026.

Sir,

Please refer to your online application through MHA portal vide I.D. No. 2021072415757 dated 24/07/2021 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 14/09/2021 in presence of Sh. Deepak Kumar to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/WZ/2020/749 dated 16.09.2020.

The Status of the Shortcomings are as under.

S. no.	Shortcomings	Status
1.	Two staircase of width of 1.0 mts & 1.50mts are provided against requirement of 1.50mts & 1.50mts.	Not Rectified
2.	Two doors of width 1.00mts each are provided against requirement of 2.00mts & 1.50mts.	Not Rectified
3.	Hose Reel not provided.	Not Rectified
4.	Down comer not Provided.	Not Rectified
5.	Fire Pump of 450lpm not Provided.	Not Rectified
6.	MOEFA were found Provided.	Rectified
7.	Fire Extinguishers were Found Provided.	Rectified
8.	Over Head Tank of 20,000 ltr Capacity is not provided.	Not Rectified

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety Arrangements shall be at the risk and liabilities of the Owner/occupier. The Licensing authority/statuary authority may take suitable necessary action as deemed fit.

Yours Faithfully

(Atul Garg)
Director

Delhi Fire Service

27/09/2021
23/09/2021

Copy To -

1. The Joint CP (Licensing), Unit, 1st Floor, Police Station, Defence Colony, New Delhi.
2. The Dy. Health Officer, West Zone, Shivaji Enclave, Rajouri Garden, New Delhi-110027