

C-47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2021/ 536

Dated: 04/10/2021

To

The Authorized Signatory,
The Akshayapatra Foundation at NP Bangali Girls Sr. Sec. School,
26, Bhai Vir Singh Marg, Sector -4, Gole Market, New Delhi.

Sub: Regarding issuance of fire NOC for running Kitchen in r/o The Akshayapatra Foundation at NP Bangali Girls Sr. Sec. School, 26 Bhai Vir Singh Marg, Sector -4, Gole Market, New Delhi .

Sir,

This has a reference to your e- mail < hr.delhi@akshayapatra.org > 30.08.21 on the subject cited above. In this regard, it is to inform you that this department has already informed vide letter no. F6/DFS/MS/Ind./NDZ/2021/175 dated 01.04.2021 (copy enclosed) that **kitchen** for cocking food is categorized under low hazard industrial occupancy and industrial building having covered area less than 250 m², does not come under Rule 27 of DFS Rules 2010. Hence, FSC is not required from this department.

Yours faithfully

Encl. as above


(Atul Garg)
DIRECTOR
011-23414000

Copy to: -

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. Sh. Narendra Singh, Jt. Director (Health & Licensing), NDMC, Palika Kendra, New Delhi-110001.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/Ind. /NDZ/2021/ 175

Dated:- 01/04/2021

To

Sh. Narender Singh,
Jt. Director (Health Licensing),
NDMC, Palika Kendra,
New Delhi.


Sub: Regarding issuance of NOC / FSC in r/o processing for grant / renewal of Health Licensing for running the trade of food at premises The Akshayapatra foundation at NP Bengali Girl Sr. sec school, 26 Bhai Veer Singh , Sector - 4 Gole Market , New Delhi -110001.

Sir,

This has a reference to your letter No. D/17/JD/SO(HL) dated 22.02.2021 on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 24.03.21 in presence of Sh. Prabhat and observed that there is a kitchen having total area 108.68 m² including dining hall, cooking and store as submitted by applicant during inspection. Kitchen is categorized under low hazard industrial occupancy and industrial building having covered area less than 250 m² , does not come under the purview of Rule 27 of Delhi Fire Service Rules 2010.

There for, FSC/ NOC from this department is not required. However, Fire safety measures shall be provided as per NBC part-4/2016 in the interest of public safety.

Yours faithfully



(Atul Garg)
DIRECTOR

Delhi Fire Service

an

Copy to :-

Sh. Aniruddha S Shinde

The Akshayapatra foundation at NP Bengali Girl Sr. Sec school, 26 Bhai Veer Singh , Sector -4
Gole Market , New Delhi -110001.