

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/SZ/ 43

Dated: 28/1.../2021

To

The HOS / Vice Principal,  
Sarvodaya Co-ed Senior Sec. School,  
Munirka Village, New Delhi 110067

Sub: Reg. renewal of Fire Safety Certificate in r/o Sarvodaya Co-ed Senior Sec. School, Munirka Village, New Delhi 110067


Sir,

This is in reference with your Gmail dated 14/01/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 15.01.2021 in presence of Mrs. Gurdeep Kaur (HOS) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Hose reel found non-functional.
2. Terrace pumps found non-functional.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat

