

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/SZ/ 530

Dated: 01/10/2021

To

(Poonam Bhatnagar)
 SES, BABA NEBHRAJ Sr. Sec. School,
 Lajpat Nagar-1, New Delhi-110017.

Sub: Issuance of NOC in r/o SES, BABA NEBHRAJ Sr. Sec. School, Lajpat Nagar-1, New Delhi-110017.

Sir,

This has reference to your BNS/NEW Clearance/21/470 dated 01/09/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 25.09.2021 in the presence of Poonam Bhatnagar (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid Hose Reel nozzle is missing.
2. Exit Signage found removed in some place.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)



Copy to:-

1. The Director of Education,
 Govt. of NCT of Delhi,
 Old Secretariat, New Delhi 110054