

C47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2021/ 540

Dated: 06/10/2021

To,

Sh. Surjan Singh (Principal)
I.T.B.P. Public School.
Sector 16 B, Dwarka, New Delhi.

Subject: Renewal of Fire Safety Certificate iro ITBP Public School Located at Sector 16 B, Dwarka, New Delhi.

Sir,

Please refer to Email dated 07-09-2021 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 22/09/2021 for the renewal of fire safety certificate.


During course of inspection the following shortcomings were observed:

1. Internal road around the building must be clear from any obstruction.
2. Two stairs provided for basement found locked.
3. Door closer of Fire check doors found removed.
4. Smoke exhaust fan in basement found removed.
5. Terrace pumps of 1620 lpm & 280 lpm not in auto mode.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054

120/c
5/10