

e-11
3-15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2021/ 438

Dated 06/10/2021

To

The Dy. Health Officer,
SDMC, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of No Objection Certificate in r/o. M/s HARAJUKU TOKYO CAFÉ (A Unit Of Craftpac Enterprises Pvt Ltd) F-40-41, First Floor, Select City Walk Mall, A-3, District Centre, Saket, New Delhi- 110017

Sir,

This has reference to with MHA Portal ID No. 2021060913716 dated 23/07/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 13.09.2021 in the presence of Mr. Gaurav to verify the fire safety measures installed in the building and observed that the building is comprised of 03 tier Basement, ground and 07 upper floors and restaurant is running at 1st floor of the building. During inspection, following points were observed:

- 1 The corridor is encroached by restaurant management and being used for seating of customer's and dinning purposes, which may create hindrance in case of emergency evacuation.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR

Copy to:

1. M/s HARAJUKU TOKYO CAFÉ (A Unit Of Craftpac Enterprises Pvt Ltd) F-40-41, First Floor, Select City Walk Mall, A-3, District Centre, Saket, New Delhi- 110017
2. The Addl. Comm. of Police (Lic) 1st Floor, P S Defence Colony, New Delhi - 110049