

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2021/ 538

Dated: 06/10/2021

To

The Principal,
Govt. Sarvodaya Kanya/Bal Vidyalaya,
Laxmi Nagar, Delhi – 110092.

Sub: Regarding Renewal of FSC in r/o Govt. Sarvodaya Kanya/Bal Vidyalaya located at Laxmi Nagar, Delhi – 110092.

Sir,

This has reference to your letter no. nil dated 09/09/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premises was visited by the officer concerned of this department on 23.09.2021 in the presence of Mr. Anil Kumar Diwedi (HOS) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested/checked and found following observation:-

1. Hose reel found not functional.
2. Fire pump found not functional.
3. Overhead water tank found empty.

Hence, Fire Safety Certificate can not be considered at this stage.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.