

C-13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS /SZ/2021/ 437

DATED: 06 /10/2021

To,

The Joint. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: Regarding issuance of NOC from fire safety point of view iro M/s Barcode A unit of the vintage boulevard Located at Plot no. 228, 3rd floor Sector – 9, Dwarka, New Delhi – 110075, New Delhi – 110075

Sir,

Please refer to Application No 2021091020917 Dated 20-09-2021 on the subject mentioned above. In this connection it is submitted that that the above said premises was visited by the officer concerned of this department on 22/09/2021 to see the compliance of the shortcomings communicated vide this office letter no. F6/DFS/MS/EH/SZ/2019/7711 dated 20/12/2019 and found that the shortcomings are still not complied. Applicant may ask to comply the shortcomings mentioned from Sl. No. 02 to 08 communicated vide above mentioned letter (Copy enclosed).

However two stairs of 1.5m each may be provided instead of 2m & 1.5m.

The preemies shall be on the risk and cost of owner/ management till the compliance of shortcomings.

In view of the above FSC from fire safety point of view cannot be considered at this stage.

Yours faithfully,

Enclose:- As Above


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. M/s Barcode A unit of the vintage boulevard Located at Plot no. 228, 3rd floor Sector – 9, Dwarka, New Delhi – 110075.
2. Deputy Health Officer, Health Department, SDMC, Dhansa stand, Najafgarh, New Delhi – 110043.