

C-21



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/WZ/2021/ 528

Dated: - 01/10/2021

To

The HOS  
Modern Child Public School,  
Nangloi, Delhi-110041.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o Modern Child Public School located at Nangloi, Delhi-110041.

Sir,

Please refer to your Email dated 31/08/2021 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Sh. Deepak Maan (Teacher) on 15/09/2021 to check the fire safety arrangements provided in the building.

During the inspection, it was also observed that the school is comprised of basement, ground plus two upper floors, served by two nos. of staircase. Fire safety arrangements such as fire extinguishers, fire pump, overhead water storage tank capacity 4000 lts etc. found provided.

However, following shortcomings were observed:-

1. Jockey pump and Terrace pump are provided but non functional.
2. First aid hose reel is provided but non functional.
3. Overhead water storage tank capacity 4000 ltrs are provided instead of 10,000 ltrs.
4. MOEFA is provided but non functional.
5. Internal hydrants are provided but non functional.
6. Automatic sprinkler system in basement floor is provided but non functional.
7. Exit Signage are provided but not adequate.
8. A multipurpose hall with sitting arrangements running in basement is not allowed as per Building bye Laws.
9. LPG cylinder placed outside the lab in corridor at 2<sup>nd</sup> floor to be shifted at ground level with fire protection arrangements.
10. Combustible material stored near to staircase at ground level to be removed.

In view of the above, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to: -

1. The Director of Education, NDMC, Civic Centre, Minto Road, New Delhi.