

C41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/ 537

Dated: 04/10/2021

To,

The Principal,
Mani Ben Patel Bhartiya Mahila Sarvodaya Kanya Vidyalaya,
G. T. Road, Shahdara, Delhi-110032

Subject:- Regarding Issuance of Fire Safety Certificate.

Sir,

With reference to email ID mbpbmschool@gmail.com dated 07/09/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. D. K. Jain, Vice Principal of the school on dated 23/09/2021. The school building comprises of ground plus three upper floors (one block) & ground plus one upper floor (three blocks). During the course of inspection following observations were made:-

1. The firefighting system which has been provided in the school building is not functional.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Joint Director of Education (Land & Estate),
Directorate of Education, Lucknow Road,
Delhi-110054