

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ/ 356

Dated: 24/08/2021

To

The Dy. Health Officer, South Zone
SDMC, Public Health Department,
Green Park, Delhi 110016

Sub: Regarding issue of Fire Safety Certificate (FSC) in r/o M/s McDonalds Family Restaurant (Connaught Plaza Restaurants Pvt. Ltd.), 1st Floor, DLF Food Court, DLF Promenade Mall, Vasant Kunj, New Delhi-110070

Sir,

This is in reference to with MHA Portal Id No 2021062314130 dated 23/06/2021 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officers concerned of this department on 10/08/2021 and observed that the shortcoming intimated vide letter of even no. 43 dated 20/01/2021 has yet not been complied. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to

1. M/s McDonalds Family Restaurant (Connaught Plaza Restaurants Pvt. Ltd.), 1st Floor, DLF Food Court, DLF Promenade Mall, Vasant Kunj, New Delhi-110070

C-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/ 2021/ 43

Dated 20/ 01/2021

To

The Dy. Health Officer,
SDMC, South Zone,
Green Park, Delhi

Sub: - Regarding issuance of fire safety certificate in r/o M/s McDonalds Family Restaurant (Connaught Plaza Restaurants Pvt. Ltd.), 1st Floor, DLF Food Court, DLF Promenade Mall, Vasant Kunj, New Delhi-110070

Sir,

This has reference to your online ID No. 2020061105322 dated 01/07/2020 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.12.2020 in the presence of Mr. Kanish Malhotra to verify the fire safety measures installed in the building and observed that Mc Donald's Family Restaurant running at 1st floor of DLF Food Court, DLF Promenade Mall, Vasant Kunj, Delhi 110070. During inspection, following points were observed:

- 1 Electric meter installed in corridor.
- 2 There is only one exit having width of 1.50 mtr against the requirement of two exits, the second exit with width of 2 mtr is also to be provided.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.

Yours faithfully


(Atul Garg)
Director

Copy to:

1. Joint C P (Lic.) P.S. Defence Colony, New Delhi (Ref. Application no. 2020061105322 dated 01/07/2020)
2. The Authorized Signature, M/s McDonalds Family Restaurant (Connaught Plaza Restaurants Pvt. Ltd.), 1st Floor, DLF Food Court, DLF Promenade Mall, Vasant Kunj, New Delhi-110070