

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/NDZ/2021/673

Dated:- 04/10/2021

To

The Manager
M.A. International,
4196, Bhagwati Bhawan, Tel Mandi,
Pahar Ganj, New Delhi.

Sub:- Regarding issuance of fire safety certificate in r/o M.A International located at 4196, Bhagwati Bhawan, Tel mandi Pahar Ganj, New Delhi. ID No 2021080917311 Dated 28.08.21.

Sir,

This has reference to online ID No 2021080917311 dated 28.08.21 on the subject cited above. In this regard, this is to inform you that the site was visited by officers concerned of this department on dated 22.09.21 in presence of Sh. Ashok Kumar and observed that fire safety arrangements such as CO type detectors and smoke management system in the guest house are not installed/provided as per Gazette Notification dated 27.05.2019. Further, the complete set of building plans including all floors are also not uploaded on the portal. Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR
Delhi Fire Service
