

c/19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/ 533

Dated: 04/10/2021

To,

The Principal,  
EDMC Pratibha Vidyalaya,  
Shivpuri (General),  
Delhi-110051

**Subject:- Application for grant of fire safety certificate in respect of EDMC Pratibha Vidyalaya, Shivpuri (Gen.).**

Sir,

With reference to letter dated 10/09/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Ruchi Jain, Incharge of the school on dated 24/09/2021. The school building comprises of ground plus two upper floors. During the course of inspection following observations were made:-

1. The firefighting system (hose reels) which has been provided in the school building is not functional.
2. A fire pump with 450 liters per minute discharge at 40 meters head (4kgf/sq.cm.) is required to be provided.


In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)

Dy. Chief Fire Officer



Copy to:-

1. The Principal,  
EDMC Pratibha Vidyalaya,  
Shivpuri (2<sup>nd</sup> Shift),  
Delhi-110051
2. The Director of Education,  
EDMC, 419, Udyog Sadan,  
Patparganj Industrial Area, Delhi-110092