



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/SZ/2021/ 417

Dated:- 23/09/2021

To,

Sh. Aman Garg (Director),
 M/s. Blue Lightning Hospitality Private Limited,
 Plot No. 20-B, Old Rajender Nagar, Pusa Road, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. Blue Lightning Hospitality Private Limited, Plot No. 20-B, Old Rajender Nagar, Pusa Road, New Delhi- 110060.

Sir,


Please refer to online application ID 2021082619089 dated 03.09.2021 on the subject cited above. Above said eating house running at third floor of a building comprised of basement, stilt, ground plus three upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on 09.09.2021 in presence of Mr. Aman Garg (Director).

During the course of inspection it has been observed that fire safety arrangements such as fire extinguishers, First aid hose reels, MOEFA, PA system etc. found provided, However the following shortcomings have been observed:-

- 1 Fire Check Doors are not provided in kitchen.
- 2 Electrical fire pump provided capacity of 1200 LPM against required capacity main electric pump 2280 LPM and standby diesel pump of 2280 LPM capacity along with jockey pump of 180 LPM.
- 3 Alternate stair width varies from 1.18 to 1.25 mts. against required 1.50 mts.
- 4 Underground water tank provided 3 Nos. made of aluminum which are placed in basement against required of 1,00,000 ltr as per NBC.
- 5 Draw-off connection found not provided.

Keeping in view of above, fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter.

Yours faithfully



(Atul Garg)

Director

Ph: 011-23414000

Copy to:-

1. The Executive Engineer (Building), North MCD, Karol Bagh, Anand Parbat, New Delhi.