

C17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/NDZ/ 439

Dated: 07/10/2021

To,

Sh. Udaya Kumar,
Sagar Ratna Restaurants Pvt. Ltd.,
Shop No. 251/3, Ground Floor,
Krishna Nagar Gandhi Nagar,
Delhi-110051

Subject:- Issuance of Fire Safety Certificate.

Sir,

With reference to online letter No. 2021070714772 dated 25/08/2021 on the subject cited above, it is informed that officer concerned of this department inspected the premises in presence of Sh. Rama Shankar, Manager on dated 28/09/2021 and observed that the shortcomings issued vide letter No F.6/DFS/MS/EH/2013/1442 dated 23/05/2013, No. F.6/DFS/MS/EH/2019/NDZ/6737 dated 14/11/2019 & F.6/DFS/MS/EH/2020/NDZ/624 dated 11/05/2020 have not been complied as yet (The copy of the same is enclosed for your reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Dy. Health Officer,
EDMC, Health Department, Karkardooma,
South Zone, Shahdara,
Delhi-110092

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

Ph - 23414333 Fax - 23412593 Email - cfohq.dfire@nic.in

No. F6/DFS/MS/EH/2013/1442

Dated: 23/05/13

To,

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone,
Karkardooma, Delhi.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Shree Rathnam Restaurants Pvt. Ltd, Shop No.251/3, Post Office Block, Krishna Nagar, Delhi-51.

Sir,

Please refer to your letter dated 20.03.13 on the above cited subject, In this connection this is to inform you that officer concerned of this department inspected the premises to verify the fire safety arrangements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010. At the time of inspection Mr. Sandeep, Manager was present and observed that the building is comprised of ground plus two upper floors. During the course of inspection, it was also noticed that-

1. The width of staircases is 1.1m as against this requirement of 1.5 m.
2. The width of door size 2 m each is required.

Due to which the building cannot be considered for issuance of Fire Safety Certificate.

Yours faithfully

(Dr. G.C. Misra)

Chief Fire Officer
Delhi Fire Service



Copy to:-

Shree Rathnam Restaurants Pvt. Ltd.

N-161/A, 5th Floor, Community Centre, Gautam Nagar, New Delhi-49.