

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/ 2021/ *w2/E4/62*  
To

Dated *29/01* /2021

Sh. Luv (Manager)  
1<sup>st</sup> Floor, Plot No-11, Block-02,  
First floor, Roop Nagar, Delhi-110007.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s B Lounge at Plot No 11, Block- 02,  
First floor, Roop Nagar, Delhi-110007.


Sir,

This has reference to your online I. D. No. 20201111108424 dated 11.11.2020 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.01.2021 in the presence of Mr. Luv (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has observed that the building/ premise is comprised of basement, stilt, ground & 03 upper floors (Restaurant on First floor only). Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 There are two staircases having width of 1.50m & 1.40m provided against the requirement of 02m & 1.5m.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.

Yours faithfully



(Atul Garg)  
Director

Ph: 011-23414000

*etc*

Copy to :

- 1 The Dy. Health Officer, Civil Line Zone, 16, Rajpura Road, Delhi-110054.
- 2 The Additional Commissioner of Police/ Lic, 1st Floor, PS Defence Colony, New Delhi.