

C/7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFs/ms/SH/2021/424

Dated: 28/09/2021

To,

Authorized Signatory,
M/s CSK Foods (Niruls),
E-128, Amar Colony, Lajpat Nagar,
New Delhi-110024.

Subject: Inspection report of M/s CSK Foods (Niruls) E-128, Amar Colony, Lajpat Nagar, New Delhi-110024 from Fire Safety and means of escape point of view.

Sir,

Please refer to your MHA ID-2021080416771 dated 09/08/2021 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officers concerned of this department on 14.09.2021 in the presence of Sh. Manoj and observed that eating house is situated on ground floor only in a building comprising Ground & Three upper floors.

Following shortcomings were observed during time of inspection:-

1. Two doors of width 1.00 mtr & 0.80mtr are provided against requirement of two doors of 1.50 mtr width each.
2. Smoke management system not provided.
3. Hose reel hose not provided.
4. MOEFA not provided.
5. Internal Hydrant not provided.
6. A Fire pump on terrace having capacity 450 LPM is not provided.
7. Overhead tank capacity of 20,000 ltr connected to fire pump is not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR.

Copy to:-

1. Dy. Commissioner of Police (Licensing), Police Station, 1st Floor, Defence Colony, New Delhi-110049.
2. Dy. Heath officer, SDMC, South Zone, Green Park, New Delhi.