

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2021/NDZ/ 545

Dated 07/10/2021

To,

The Principal,
EDMC Primary School,
Khera, G.T Road, (Gen)
Shahdara North, Delhi 110095

Sub:- Regarding Issuance Fire Safety Certificate.

Sir,

This is in reference to your Email. dated 27/07/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Subhash Chandra (Principal) of the School on 06/09/2021. During the course of inspection, the following points / shortcomings were noticed in the building comprised of ground plus two upper floors.

1. A fire pump having 220 liters per minute provide in place of 450 LPM Output at 40 meters head as required.
2. Over Head water storage tank 10,000 liters capacity exclusively for fire fighting not provided at terrace.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92