

C-40

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No.F6/DFS/MS/EH/WZ/School/2021/546

Dated:- 07/10/2021

To,

The Principal  
Guru Tegh Bhadur 3<sup>rd</sup> Century Public School  
C- Block, Mansarovar Garden  
New Delhi - 110015

**Subject: Regarding renewal of NOC in respect of M/s Guru Teg Bahadur 3<sup>rd</sup> century Public School Located at C-Block, Mansarovar Garden, New Delhi-110015.**

Sir,

With reference to your Email dated 15/09/2021 on the subject cited above. In this connection, it is to inform you that the said premises/building was inspected by the officer concerned of this department on 22/09/2021 in the presence of Sh. Ravi Kumar to check the shortcomings already issued by this department vide letter No.F6/DFS/MS/SCHOOL/MN/441 dated 27/08/2021. During inspection, it has been observed that the premise was comprised of Ground plus two upper floors. Fire safety arrangements such as, Fire Extinguishers, Hose reels, Terrace pump etc. are provided. However the statuses of shortcomings are as under.

S. no.	Shortcomings	Status
1.	First Aid Hose reels are Provided but found leakage.	Rectified
2.	Terrace Fire Pump of 450 lpm is provided but not working.	Not Rectified (Not on auto mode)
3.	Overhead water storage tank of capacity 10,000 lts is found removed.	Not Rectified
4.	Exit Signage's found removed.	Not Rectified.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully

5/10/2021  
Dharampal Bhardwaj  
Dy. chief Fire Officer  
West Zone

o/c  
04/10/2021

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE,  
NEW DELHI-110001**

No. F/DF/S/MS/School/MN/ 441

Dated 27/08/2021

To,

The Principal,  
Guru Tegh Bahadur 3<sup>rd</sup> Centenary Public School,  
C Block, Mansarovar Garden,  
New Delhi - 110015.

Sub:- Inspection report in respect of Guru Tegh Bahadur 3<sup>rd</sup> Centenary Public School, C Block, Mansarovar Garden, New Delhi - 110015.


Madam,


With reference to your Email dated 26/07/2021 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 19/08/2021 in the presence of Sh. Ravi Kumar to see the functioning of the fire safety equipments provided in the building. During inspection, it has been observed that the premises was comprised of Ground plus two upper floors was issued FSC vide letter No.F/6/MS/DF/S/School/2018/1910 dated 16/08/2018. Fire safety arrangements such as, Fire Extinguishers, Hose reels, Terrace pump etc. are provided. However, following shortcomings were observed:-

1. First Aid Hose reels are provided but found leakage.
2. Terrace fire pump of 450l pm is provided but not working
3. Overhead water storage tank of capacity 10,000 ltrs is found removed.
4. Exit signage's found removed.

In view of above shortcomings, the application for Renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
Delhi Fire Service

  
26/08/2021

Copy to:-