

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/2021/WZ/ 543

Dated: 07/10/2021

To,

Er. Amar Chand Meena,  
A.E (Electrical)  
PWD Sub-Division 4,  
Edu. Elect. Edn.1 Div. (N)  
Zakhira, Rama Road, Delhi-110015.

**Sub:- Issuance of Fire Safety Certificate in respect of SKV No. 2 (School ID 1310170) ,  
Narela, Delhi-110040.**

Sir,

Please refer to your email id dated 22.09.2021 on the subject cited above. In this connection it is to inform you that the premises was visited by officer concerned of this department on 28.09.2021 and observed that due to non availability of permanent electricity connection inspection of fire pumps could not be carried out.

You are requested to re-apply when electricity is made available to Fire pumps.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service