

G-16

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2021/SZ/ 544

Dated: 07/10/2021

To,

The Principal,  
Nigam Pratibha Vidyalaya,  
B-2-B, Janakpuri, New Delhi-110058

**Sub:** - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Nigam Pratibha Vidyalaya, B-2-B, Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter no. Nil Dated- 25/08/2021 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 21/09/2021 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Smt. Sushma Mittal (Principal) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. First aid hose reel not provided.
2. Fire pump having 450 lpm not provided.
3. Overhead tank capacity of 10,000 ltrs not provided.
4. Exits signage's are not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

  
(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Principal, Nigam Pratibha Vidyalaya, B-2-B, Janakpuri, New Delhi-110058
  2. The Director of Education, SDMC Civic, Minto Road, New Delhi-110001.
- (with a request to take further action as school does not have fire NOC)