

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2021/ 541

Dated: 07/10/2021

To,

The Head of Office,
Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya,
New Rajinder Nagar, New Delhi- 110060.


Sub.:- Regarding renewal of Fire Safety Certificate in r/o Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya, New Rajinder Nagar, New Delhi- 110060.

Sir,

Please refer to your letter No. RPSV/NRN/2021/379 dated 17.09.2021 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 24.09.2021 in presence of Sh. Anirudh Parsad (Estate Manager) to check the status of the shortcomings pointed out by this department in earlier inspection vide letter No. F.6/DFS/MS/School/SZ/2018/3323 dated 06.08.2018, but no improvement was observed as seen during the course of inspection.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the fire safety arrangements under intimation to this department.

Yours faithfully



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

o/c B

Copy to: -

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi

for information please

C-14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2018/ 3323

Dated: - 6/8/18

To

Head of Office,
Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya,
New Rajinder Nagar, New Delhi- 110060.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya, New Rajinder Nagar, New Delhi- 110060.

Sir,


Please refer to your letter No. nil dated 05.04.2018 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Sh. Ishwar Chand, Principal of the school, on 28/06/2018 to check the fire safety arrangements. The school building was granted FSC by this department vide letter No. F6/DFS/MS/School/2015/SZ/209 dated 11.02.2015 for ground plus one upper floor.

During the inspection, it was also observed that the school management has constructed one more upper floor and now the school building is comprised of ground plus two upper floors, served by three staircase having width 1.30, 1.50 & 1.33 mts from ground to first floor and two nos. of staircases having width 1.50 & 1.33 mts from first floor to second floor. No fire safety arrangement found provided except few fire extinguishers. Following fire safety arrangements are required: -


1. Width of alternate staircase shall be atleast 1.5 mts.
2. First aid hose reel at each floor.
3. Terrace pump having capacity atleast 450 LPM.
4. Overhead water storage tank capacity 10000 lts shall be provided exclusively for firefighting purpose.

In view of the above, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully



(VIPEN KENTAL)
CHIEF FIRE OFFICER



Copy to: -

1. The Principal, Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya, New Rajinder Nagar, New Delhi- 110060.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

for information please.