

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2021/ 553

Dated: 07/10/2021

To

The Principal,
New Sun Ideal Public school,
T-505, Chamelian Road, Delhi-110006.

**Sub: Regarding Renewal of FSC in r/o New Sun Ideal Public School located at T-505,
Chamelian Road, Delhi-110006.**

Sir,

This has reference to your e-mail <new_sun_education@yahoo.com> dated 10/08/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 27.09.2021 in the presence of manager and observed that alternate staircase is still not provided continuous from ground to upper as communicated earlier vide letter NO. F6/DFS/MS/School/2020/ 668 &57& 321 dated 06.10.2020 & 05.02.21 & 01/07/2021 respectively.

In view of above, fire safety certificate (FSC) cannot be renewed at this stage .

Encl : as above

Yours faithfully



(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-
The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.



**Sub: Regarding Renewal of FSC in r/o New Sun Ideal Public school located at T-505,
Chamelian Road, Delhi-110006.**

Sir,


This has reference to your email dated 04/09/2020 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 21/09/2020 in the presence of Mr. Rizwan and the following shortcomings were observed:-

1. Hose reel hose found removed at alternate floor.
2. Fire pump not functional.
3. Over head tank capacity of additional 5,000 liter not provided.
4. Fiber sheets are to be removed wherever used.

If the student capacity is more than 45 in any class room then double door as far as possible should be provided in that class room.

You are advised to rectify the above mentioned shortcomings and apply in form J for taking further necessary action as necessary for renewal of Fire Safety Certificate.

Yours faithfully



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.