

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH/2021/SZ/ 431  
To,

Dated: 01/10/2021

Dy. Health Officer,  
South Delhi Municipal Corporation,  
Public Health Department, West Zone,  
Vishal Enclave, Rajouri Garden, New Delhi

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s DA ROOH SHALA, Shop no. 9 & 10  
GF, Ivory Tower Ajay Enclave, Subhash Nagar, New Delhi


Sir,

This has reference to letter ID No. No. 2021082619102 dated 01/09/2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officers concerned of this department on 21/09/2021 in presence of Sh. Rajesh Wadhawan. During the course of inspection it was observed that the building is comprised of two tier basement, ground plus four upper floors but eating house running at ground floor only. The following shortcomings were observed:-

1. Exits of restaurant 1.0 m provided instead of 1.5 m each.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours Faithfully

  
(Atul Garg)  
Director

Delhi Fire Service

9/10

Copy to:-

The Manager,  
M/s Quisine Hospitality & Co., Shop No.-9 & 10,  
GF, Ivory Tower Ajay Enclave, Subhash Nagar, New Delhi