

035

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2021/ 446

DATED: 08/10/2021

To,
Mr. Madhur Sharma (Deputy Manager- Legal),
M/s KFC Restaurant Plot No. 230,
Sector – 9, Dwarka, New Delhi – 110077.

Subject: Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o M/s KFC Restaurant Located at Plot No. 230, Sector – 9, Dwarka, New Delhi – 110077.

Sir,
Please refer to Email dated 17/09/2021 on the subject mentioned above. In this connection it is submitted that that the above said premises was visited by the officer concerned of this department on 30/09/2021 to see the compliance of the shortcomings communicated vide this office letter no. F6/DFS/MS/SZ/2021/105 dated 24/02/2021 and found that the shortcomings are still not complied. You are requested to comply the shortcomings under intimation with this department.

In view of the above FSC from fire safety point of view cannot be considered at this stage.

Yours faithfully,

(Sunil Chaudhary)
(Dy. Chief Fire Officer)
Delhi Fire Service

Copy to:-

The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi

C-20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2021/105

DATED: 24/02/2021

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in
r/o M/s KFC Restaurant Located at Plot No. 230, Sector – 9, Dwarka, New Delhi – 110077.

Sir,

This is in reference to your letter no. 2021020110074 Dated 02-02-2021 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 09/02/2021.

During the course of inspection followings shortcoming have been observed:-

1. One Terrace pump of 180 LPM found Removed. All the pumps must be functional in auto mode.
2. Overhead water storage tank of 5000 litres capacity found provided against required 10000 ltrs capacity. The tank must be exclusively for fire fighting.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

Mr. Suraj (Manager) M/s KFC Restaurant Plot No. 230, Sector – 9, Dwarka,
New Delhi – 110077.

20/2/21