GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

Dated: 08/10/2021



1)The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi

2)The Deputy Commissioner of police, (SW), Dwarka, New Delhi.

3) The Commissioner, North Delhi Municipal Corporation, Civic Centre, Minto Road, New Delhi -110002.

Subject: Renewal of Fire Safety Certificate iro Kanchan house Located at A-1, Nishant Park near kakrola Dwarka mor Delhi – 110078.

Sir,

Please refer to Application No 2021082018344 dated 24-08-2021 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 20/09/2021 for the renewal of fire safety certificate. During course of inspection the following shortcomings were observed:

- 1. The width of access road is less than 12m.
- 2. One staircase of 108 cm found provided against required two staircases of 150 cm clear width.
- 3. Fire check doors of one hour fire rating are found not provided.
- 4. The width Of Corridor is less than 1.8 M.
- 5. Smoke managements System at upper floors found not provided.
- 6. Hose reel hose found non functional.
- 7. CO detector are found not provided.
- 8. MOEFA found not provided.
- 9. Public Address System found not provided.
- 10. Terrace pump of 900 lpm found not provided.

11. During the visit it is observed that the guest house is being run without any fire safety certificate.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully.

Delhi Fire Service

Copy to:- 1. Mr Aman (Manager) Kanchan house A-1, Nishant Park near kakrola Dwarka mor Delhi – 110078.

2. The Dy. Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.