

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C32

N DFS/MS/SCHOOL/MN/ 555

Dated: 11/10/2021

To

The Principal,
Guru Nanak Public School,
West Avenue, Punjabi Bagh,
New Delhi - 110026

Subject: - Inspection report in respect of Guru Nanak Public School, Punjabi Bagh, New Delhi - 110026.

Sir,

Please refer to your Email dated 14/09/2021 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 21/09/2021 in presence of Sh. Durga Prasad (Care Taker) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/SCHOOL/MN/138 dated 12.03.2021. During inspection, it has been observed that the said building is comprised of Ground plus Three upper floors (New Building), Ground plus two upper floors (Old Building) & Ground plus one upper floor (office Block). All are inter connected served by four staircases. Fire Safety arrangements such as Fire Extinguishers, First Aid Hose reels, terrace pump, Overhead water storage tank & Exit signage are provided. However the Status of the Shortcomings are as under.

S. no.	Shortcomings	Status
1.	One Staircase (Iron) found blocked.	Rectified
2.	First-Aid Hose Reels are found leakage and non functional.	Not -Rectified
3.	Fire Pump is not found on automode.	Not -Rectified
4.	Exit Signage's found removed.	Not -Rectified
5.	Overhead water storage tank 10,000 capacity is not provided.	Not -Rectified

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutorily authority may take suitable necessary action as deemed fit.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To: -

1. The directorate of Education, old secretariat, Delhi.

07/10/2021