

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/School/2021/ 556

Dated 11 / 10 / 2021

To,

The Principal  
 Govt. Boys Sr. Sec. School,  
 Dhakka, Delhi-110009.

Sub: - Regarding issuance of fire safety certificate in r/o Govt. Boys Sr. Sec. School, (I.D No-1309022) located at Dhakka, Delhi-110009.

Sir,

Please refer to your letter received through email I.D dated 20.09.2021 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 22.09.2021 to verify the fire safety measures issued vide NBC Part 4 and observed that the school premise is comprised of 03 Blocks (02 blocks ground + 01 and 01 blocks ground + 03 upper floors. At the time of inspection Dr. Mahesh Kumar, Principal was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Fire extinguisher provided in the building were checked and found short in no total 30nos required.
2. Hose reel hose provided in G+03 blocks but found not functional and some nozzles are missing.
3. Terrace level fire fighting pump capacity of 450lpm each provided in G+03 blocks but found not functional.
4. Terrace level fire water tank capacity of 10,000ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only
5. Exit signage found removed at some places.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully

(Dharampal Bhardwaj)  
 Dy. Chief Fire Officer  
 Ph:-011-25156707

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.