

C-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2021/ 441

Dated 07/10/2021

To

The Dy. Health Officer,  
SDMC, Health Department, South Zone,  
Green Park, Delhi -110016

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s SANDOZ Restaurant (SANDOZ Restaurant Pvt. Ltd), at GF 6 & 8, Chiranjiv Tower, 43, Nehru Place, New Delhi-110017

Sir,

This has reference to your MHA Portal ID 2021090119693 dated 01/09/2020 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 18.09.2021 in the presence of Mr. Sudhir (Manager) to verify the fire safety measures installed in the building and observed that the restaurant is running at Ground and Mezzanine floor. During inspection, following points were observed:

1. There is only one staircase provided in the restaurant for mezzanine floor having width of 1.50 mtr. The alternative staircase having width of 1.50 mtr is also needed as per UBBL-2016.
2. There is only one door provided in the restaurant having width of 2.0 mtr wide. The second alternative exit door having width of 1.50 also need to be provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(Atul Garg)  
Director  
9/10

Copy to:

1. Joint C P (Lic.) P.S. Defence Colony, New Delhi 110049
2. The Authorized Signature, M/s SANDOZ Restaurant (SANDOZ Restaurant Pvt. Ltd), at GF 6 & 8, Chiranjiv Tower, 43, Nehru Place, New Delhi-110017.