

C-38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DHS/MS/EH/2021/447

Dated: 12/10/2021

To,

Vipin Kumar,
M/s Wok in the Clouds (A Unit of Edesia Hospitality (P) Ltd.)
Flat No.-22, 1st Floor & 2nd Floor, Khan Market, New Delhi.

Subject: Inspection report of M/s Wok in the Clouds (A Unit of Edesia Hospitality (P) Ltd.) Flat No.-22, 1st Floor & 2nd Floor, Khan Market, New Delhi from Fire Safety and means of escape point of view.

Sir,

Please refer to your MHA portal ID-2021091121055 dated 11/09/2021 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officers concerned of this department on 01.10.2021 in the presence of Sh. Vipin Kumar and observed following shortcomings during the inspection:-

1. Only one staircase of width 1.00m is provided against requirement of 2 staircases of width 1.50mtr each.
2. Hose reel hose provided but found non functional.
3. MOEFA not provided.
4. Internal Hydrant provided but non-functional.
5. Over Head Tank of 5,000 ltr is provided against requirement of 20,000 ltr capacity.

In view of above NOC/ FSC cannot be considered at this stage.

The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR.

Copy to:-

1. Addl. Commissioner of Police (Lic), 1st Floor, PS defence colony, New Delhi-110049.