



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/ 563

Dated: 13/10/2021

To,

The Principal,
EDMC Primary School,
South Gandhi Nagar, Delhi-110031

Subject:- Issuance of Fire Safety Certificate.

Sir,

With reference to your letter dated 23/09/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school building from fire safety point of view in presence of Ms. Barkha, Incharge of the school on dated 05/10/2021, it was observed that the shortcomings issued vide letter No. F.6/DFS/MS/School/2015/1923 dated 21/08/2015 have not been complied as yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours Faithfully,

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

1. The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-92
2. The Principal (2nd Shift),
EDMC Primary School,
South Gandhi Nagar, Delhi-110031

C-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS(MS) School/2015/1923
To,

Dated 21/08/15

The Principal
EDMC Primary School,
S. Gandhi Nagar, Delhi-31

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o EDMC Primary School, S. Gandhi Nagar, Delhi-31


Madam,

Please refer to your letter dated 17.07.2015 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Principal was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings:-

1. First Aid Hose reels not provided.
2. Fire pump having capacity 450 LPM out put at 40 m head not provided.
3. Over head water storage tank 10,000 liters capacity for firefighting not provided.
4. Exit signs not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under intimation to this department for further course of action.

Yours faithfully


(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

Copy to:-

- 1 The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92
2. The Principal (2nd Shift)
✓ EDMC Primary School, S. Gandhi Nagar, Delhi-31