

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2021/ 53

Dated: - 03/02/2021

To

The Director,  
Manav Sthali School,  
Dobule Storey, New Rajinder Nagar,  
New Delhi- 110060.

Sub.:- Regarding renewal of Fire Safety Certificate in r/o Manav Sthali School located at Double Storey, New Rajinder Nagar, New Delhi- 110060.

Sir,

Please refer to received your letter No. MSGS/DS/2021/476 dated 11.01.2021 on the subject cited above. In this connection, it is to inform you that the aforesaid school building is comprised of ground plus three upper floors. School building have been inspected by the officer concerned of this department in presence of Mr. Vijay Chabra (Estate Manager) on 19.01.2021 to check the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that according to FSC issued by this department vide letter no. F.6/DFS/MS/School/SZ//2017/947 dated 04.07.2017, school building comprised of ground plus two upper floors, but at the time of inspection it was observed that the school management constructed one additional floor i.e. third floor made of wooden structure. It is a case of addition/alteration in school building.

In view of the above renewal of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to submit sanctioned plan of school building if any to this department for further action in the matter.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to: -

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi-

for information please