## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001 DFS/MS/WZ/2021/456 Dated: 4/6/2021

To,

The Addl. Commissioner of Police (Lic), 1<sup>st</sup> Floor, Licensing Unit, Police Station, Defence Colony, New Delhi,

## Sub.: - <u>Regarding grant of Fire Safety certificate r/o M/s Sagar Ratna Restaurant Located FD-</u> 2, Ground Floor, Pitampura, New Delhi-110034.

Sir,

This has reference to your online application no. 20210903200 62 dated 06.09.2021 on the subject cited above. In this connection it is to inform you that the above said Restaurant building was inspected by the officer concerned of this department from safety point of view on 29.09.2021 in the presence of Sh. Sanjunath (Manager) to check compliance of the shortcomings communicated vide this department letter no. F6/DFS/MS/2017/2180 dated 22.08.2017.

During the course of inspection it has been observed that the management has rectified some of the shortcomings & present status is as under:-

SI. No	Shortcommes	Status
1.	Two exit of 1m & 89cm width are provided instead of 2m & 1.5 m clear width.	2 <sup>nd</sup> exit 1.5 m wide not yet provided
2.	First Aid Hose Reel Hose & down comer system are not provided	Not yet Provided
3.	Manual Operated Emergency Fire alarm system is not provided.	Provided
4.	Terrance Pump of 450 lpm not provided	Not yet provided 280 lpm provided instead of 450 lpm
5.	Over Head Tank of 20000 liters. not provided	Provided
).	Exit Sign. are not provided	Not yet Provided

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithin (Atul Gar Director

Copy to:-

1. Sh. Udaya Kumar, M/s Sagar Ratna Restaurant Located FD-2, Ground Floor, Pitampura, New Delhi-110034.

1 1 met