

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F-6/DFS/MS/School/ 2021/ 562

Dated 13/10/2021

To

The Principal  
Sarvodaya Kanya Vidyalaya  
Pratap Nagar, Delhi-110007.

**Sub:** Regarding issuance of fire safety certificate in r/o Sarvodaya Kanya Vidyalaya, (I.D No.1208014 & 1208232), Pratap Nagar, Delhi-110007.

Sir,

Please refer to your letter received through email I.D dated 20.09.2021 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 29.09.2021 in the presence of Smt. Shalini Chauhan (Incharge) to verify the fire safety measures provided in the building and observed that the school premise is comprised of 03 blocks (02 blocks ground + 01 upper floor and 01 block ground + 03 upper floors. The observations and shortcomings were noticed at the time inspection.

- 1 Fire extinguisher provided in the building were checked and found short in no.
- 2 Hose reel hose provided in G+03 blocks but found not functional and some nozzles are missing.
- 3 Terrace to ground floor lending valve not provided.
- 4 Terrace level fire fighting pump capacity of 450lpm provided in G+03 blocks but found not functional.
- 5 Terrace level fire water tank capacity of 10,000ltrs empty and water filling source not provided.
- 6 Exit signage not provided at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully

(Atul Garg)  
Director

Ph: 011-23414250

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.