

C-78

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/MN/ 25

Dated: 18 / 10 / 2021

To

Sh. Shiv Kumar Sahdev
Officiating Principal
Shivaji College University of Delhi
New Delhi - 110027.

Sub: - Regarding issuance of Fire safety Certificate in respect of Shivaji College University of Delhi, New Delhi-110027

Sir,

Please refer to your email dated 22.09/2021 on the subject cited above in this regard it is to inform you that the above said Building/ Premises has been inspected by the officer concerned of this department on 06.10.2021 in the presence of Sh. Hemant Lamba (admin officer) to check the workability of fire safety arrangements provided in the building.

During inspection it has been observed that the school building is comprised of Stilt/Ground + 03 Upper Floors served by two staircase and one ramp. Fire safety arrangement such as Overhead water storage tank, terrace pump, MOEFA, Internal hydrant, hose reel, exit signage,, Fire Extinguisher, D.G.Set etc. Found provided.

However, the following shortcomings were observed :-

1. 06 mts wide internal road in one side is blocked. The trees on the 06 mts wide road shall be trimmed/removed.

In view of the above shortcomings, the application for issuance of fire safety certificate is rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/Occupier.

Yours Faithfully

Atul Garg
Director

Delhi Fire Service

Copy To: -

1. The Executive Engineer (Building),
Building Department, SDMC, 8th Floor, Civic Center,
Minto Road, New Delhi

o/c
14/10/2021